ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
190220580022013	Whittier	Elementary School	4/20/18	6:34 AM	DO	WH01A	Nurse's Office	S - Sink	4/19/2018	7:25 PM	First Draw	250	ARRO Laboratory	EPA 200.5	7.10	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:34 AM	DO	WH01B	Nurse's Office	S - Sink	4/19/2018	7:25 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:38 AM	DO	WH02A	Room 3	S - Sink	4/19/2018	7:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:40 AM	DO	WH02B	Room 3	S - Sink	4/19/2018	7:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.99	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:41 AM	DO	WH03A	Room 4	S - Sink	4/19/2018	7:02 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:41 AM	DO	WH03B	Room 4	S - Sink	4/19/2018	7:02 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:42 AM	DO	WH04A	Room 6	S - Sink	4/19/2018	7:09 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:45 AM	DO	WH04B	Room 6	S - Sink	4/19/2018	7:09 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:45 AM	DO	WH05A	Room 7	S - Sink	4/19/2018	7:12 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.44	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:45 AM	DO	WH05B	Room 7	S - Sink	4/19/2018	7:12 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:48 AM	DO	WH06A	Room 12	S - Sink	4/19/2018	7:45 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:48 AM	DO	WH06B	Room 12	S - Sink	4/19/2018	7:45 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:49 AM	DO	WH07A	Room 13	S - Sink	4/19/2018	7:43 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.35	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:50 AM	DO	WH07B	Room 13	S - Sink	4/19/2018	7:43 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:50 AM	DO	WH08A	Room 19	S - Sink	4/19/2018	7:31 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:51 AM	DO	WH08B	Room 19	S - Sink	4/19/2018	7:31 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:57 AM	DO	WH09A	Room 21	S - Sink	4/19/2018	7:28 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022013	Whittier	Elementary School	4/20/18	6:57 AM	DO	WH09B	Room 21	S - Sink	4/19/2018	7:28 PM	Flush	250	ARRO Laboratory	EPA 200.5	8.36	2.00	