

Henry Puffer Elementary School 2220 Haddow Ave. Downers Grove, IL

ISBE ID	Sample	Sample	Sample ID	Sample Location Description	Fixture Type	Date of Last	Time of	Sample	Concentration
	6/2/2023	5:35:00 AM	HPES01A	Hallway Outside CR104 - Left	DF - Drinking Fountain	6/1/2023	10:47 PM	First Draw	<2.0 µg/L
	6/2/2023	5:35:00 AM	HPES01B	Hallway Outside CR104 - Left	BF - Bottle Filler	6/1/2023	10:47 PM	First Draw	<2.0 µg/L
	6/2/2023	5:37:00 AM	HPES01C	Hallway Outside CR104 - Left	DF - Drinking Fountain	6/1/2023	10:47 PM	Flush	<2.0 µg/L
	6/2/2023	5:37:00 AM	HPES02A	Hallway Outside CR104 - Right	DF - Drinking Fountain	6/1/2023	10:45 PM	First Draw	<2.0 µg/L
	6/2/2023	5:42:00 AM	HPES02B	Hallway Outside CR104 - Right	DF - Drinking Fountain	6/1/2023	10:45 PM	Flush	<2.0 µg/L
	6/2/2023	5:42:00 AM	HPES03A	Hallway Outside Multipurpose Room - Left	DF - Drinking Fountain	6/1/2023	10:55 PM	First Draw	<2.0 µg/L
	6/2/2023	5:42:00 AM	HPES03B	Hallway Outside Multipurpose Room - Left	BF - Bottle Filler	6/1/2023	10:55 PM	First Draw	<2.0 µg/L
	6/2/2023	5:42:00 AM	HPES03C	Hallway Outside Multipurpose Room - Left	DF - Drinking Fountain	6/1/2023	10:55 PM	Flush	<2.0 µg/L
	6/2/2023	5:45:00 AM	HPES04A	Hallway Outside Multipurpose Room - Right	DF - Drinking Fountain	6/1/2023	10:53 PM	First Draw	<2.0 µg/L
	6/2/2023	5:45:00 AM	HPES04B	Hallway Outside Multipurpose Room - Right	DF - Drinking Fountain	6/1/2023	10:53 PM	Flush	<2.0 µg/L
	6/2/2023	5:52:00 AM	HPES05A	Hallway Outside CR221	DF - Drinking Fountain	6/1/2023	11:12 PM	First Draw	<2.0 µg/L
	6/2/2023	5:52:00 AM	HPES05B	Hallway Outside CR221	BF - Bottle Filler	6/1/2023	11:12 PM	First Draw	<2.0 µg/L
	6/2/2023	5:52:00 AM	HPES05C	Hallway Outside CR221	DF - Drinking Fountain	6/1/2023	11:12 PM	Flush	<2.0 µg/L
	6/2/2023	6:00:00 AM	HPES06A	Hallway Outside CR231	DF - Drinking Fountain	6/1/2023	11:45 PM	First Draw	<2.0 µg/L
	6/2/2023	6:00:00 AM	HPES06B	Hallway Outside CR231	BF - Bottle Filler	6/1/2023	11:45 PM	First Draw	<2.0 µg/L
	6/2/2023	6:00:00 AM	HPES06C	Hallway Outside CR231	DF - Drinking Fountain	6/1/2023	11:45 PM	Flush	<2.0 µg/L
	6/2/2023	6:07:00 AM	HPES07A	CR201	DF - Drinking Fountain	6/1/2023	10:39 PM	First Draw	<2.0 µg/L
	6/2/2023	6:07:00 AM	HPES07B	CR201	DF - Drinking Fountain	6/1/2023	10:39 PM	Flush	<2.0 µg/L
	6/2/2023	6:15:00 AM	HPES08A	Multipurpose Room Kitchen	S - Sink	6/1/2023	10:52 PM	First Draw	<2.0 µg/L
	6/2/2023	6:15:00 AM	HPES08B	Multipurpose Room Kitchen	S - Sink	6/1/2023	10:52 PM	Flush	<2.0 µg/L
	6/2/2023	6:18:00 AM	HPES09A	Staff Room	WC - Water Cooler	6/1/2023	10:56 PM	First Draw	<2.0 µg/L
	6/2/2023	6:18:00 AM	HPES09B	Staff Room	WC - Water Cooler	6/1/2023	10:56 PM	Flush	<2.0 µg/L
	6/2/2023	6:20:00 AM	HPES10A	Staff Room	S - Sink	6/1/2023	10:57 PM	First Draw	<2.0 µg/L
	6/2/2023	6:20:00 AM	HPES10B	Staff Room	S - Sink	6/1/2023	10:57 PM	Flush	<2.0 µg/L
	6/2/2023	6:25:00 AM	HPES11A	Nurse Sink	S - Sink	6/1/2023	11:02 PM	First Draw	<2.0 µg/L
	6/2/2023	6:25:00 AM	HPES11B	Nurse Sink	S - Sink	6/1/2023	11:02 PM	Flush	<2.0 µg/L
	6/2/2023	6:30:00 AM	HPES12A	CR213	S - Sink	6/1/2023	11:05 PM	First Draw	<2.0 µg/L
	6/2/2023	6:30:00 AM	HPES12B	CR213	S - Sink	6/1/2023	11:05 PM	Flush	<2.0 µg/L
	6/2/2023	6:35:00 AM	HPES13A	CR224	S - Sink	6/1/2023	11:20 PM	First Draw	<2.0 µg/L
	6/2/2023	6:35:00 AM	HPES13B	CR224	S - Sink	6/1/2023	11:20 PM	Flush	3.3 µg/L
	6/2/2023	6:38:00 AM	HPES14A	CR223	S - Sink	6/1/2023	11:28 PM	First Draw	<2.0 µg/L
	6/2/2023	6:38:00 AM	HPES14B	CR223	S - Sink	6/1/2023	11:28 PM	Flush	<2.0 µg/L
	6/2/2023	6:42:00 AM	HPES15A	CR228	S - Sink	6/1/2023	11:34 PM	First Draw	<2.0 µg/L
	6/2/2023	6:42:00 AM	HPES15B	CR228	S - Sink	6/1/2023	11:34 PM	Flush	<2.0 µg/L
	6/2/2023	6:44:00 AM	HPES16A	CR233	S - Sink	6/1/2023	11:40 PM	First Draw	4.2 µg/L
	6/2/2023	6:44:00 AM	HPES16B	CR233	S - Sink	6/1/2023	11:40 PM	Flush	<2.0 µg/L