

Lester Elementary School 236 Indianapolis Ave. Downers Grove, IL

ISBE ID	Sample	Sample	Sample ID	Sample Location Description	Fixture Type	Date of Last	Time of	Sample	Concentration
	5/31/2023	6:33:00 AM	LE01A	HW outside CR115	DF - Drinking Fountain	5/30/2023	8:55 PM	First Draw	<2.0 µg/L
	5/31/2023	6:33:00 AM	LE01B	HW outside CR115	BF - Bottle Filler	5/30/2023	8:55 PM	First Draw	<2.0 µg/L
	5/31/2023	6:33:00 AM	LE01C	HW outside CR115	DF - Drinking Fountain	5/30/2023	8:55 PM	Flush	<2.0 µg/L
	5/31/2023	6:36:00 AM	LE02A	HW outside CR113	DF - Drinking Fountain	5/30/2023	6:38 PM	First Draw	<2.0 µg/L
	5/31/2023	6:36:00 AM	LE02B	HW outside CR113	BF - Bottle Filler	5/30/2023	6:38 PM	First Draw	<2.0 µg/L
	5/31/2023	6:36:00 AM	LE02C	HW outside CR113	DF - Drinking Fountain	5/30/2023	6:38 PM	Flush	<2.0 µg/L
	5/31/2023	6:38:00 AM	LE03A	CR110	S - Sink	5/30/2023	9:38 PM	First Draw	<2.0 µg/L
	5/31/2023	6:38:00 AM	LE03B	CR110	S - Sink	5/30/2023	9:38 PM	Flush	<2.0 µg/L
	5/31/2023	6:40:00 AM	LE04A	CR111	S - Sink	5/30/2023	9:35 PM	First Draw	<2.0 µg/L
	5/31/2023	6:40:00 AM	LE04B	CR111	S - Sink	5/30/2023	9:35 PM	Flush	<2.0 µg/L
	5/31/2023	6:44:00 AM	LE05A	HW outside CR109	DF - Drinking Fountain	5/30/2023	6:34 PM	First Draw	<2.0 µg/L
	5/31/2023	6:44:00 AM	LE05B	HW outside CR109	BF - Bottle Filler	5/30/2023	6:36 PM	First Draw	<2.0 µg/L
	5/31/2023	6:44:00 AM	LE05C	HW outside CR109	DF - Drinking Fountain	5/30/2023	6:34 PM	Flush	<2.0 µg/L
	5/31/2023	6:47:00 AM	LE06A	CR112	S - Sink	5/30/2023	9:41 PM	First Draw	<2.0 µg/L
	5/31/2023	6:47:00 AM	LE06B	CR112	S - Sink	5/30/2023	9:41 PM	Flush	<2.0 µg/L
	5/31/2023	6:50:00 AM	LE07A	CR113	S - Sink	5/30/2023	9:40 PM	First Draw	<2.0 µg/L
	5/31/2023	6:50:00 AM	LE07B	CR113	S - Sink	5/30/2023	9:40 PM	Flush	<2.0 µg/L
	5/31/2023	6:52:00 AM	LE08A	CR114	S - Sink	5/30/2023	9:42 PM	First Draw	<2.0 µg/L
	5/31/2023	6:52:00 AM	LE08B	CR114	S - Sink	5/30/2023	9:42 PM	Flush	<2.0 µg/L
	5/31/2023	6:55:00 AM	LE09A	CR115	S - Sink	5/30/2023	9:19 PM	First Draw	<2.0 µg/L
	5/31/2023	6:55:00 AM	LE09B	CR115	S - Sink	5/30/2023	9:19 PM	Flush	<2.0 µg/L
	5/31/2023	6:59:00 AM	LE10A	HW outside gymnasium	DF - Drinking Fountain	5/30/2023	6:29 PM	First Draw	<2.0 µg/L
	5/31/2023	6:59:00 AM	LE10B	HW outside gymnasium	BF - Bottle Filler	5/30/2023	6:29 PM	First Draw	<2.0 µg/L
	5/31/2023	6:59:00 AM	LE10C	HW outside gymnasium	DF - Drinking Fountain	5/30/2023	6:29 PM	Flush	<2.0 µg/L
	5/31/2023	7:04:00 AM	LE11A	HW outside CR103	DF - Drinking Fountain	5/30/2023	6:26 PM	First Draw	<2.0 µg/L
	5/31/2023	7:04:00 AM	LE11B	HW outside CR103	BF - Bottle Filler	5/30/2023	6:26 PM	First Draw	<2.0 µg/L
	5/31/2023	7:04:00 AM	LE11C	HW outside CR103	DF - Drinking Fountain	5/30/2023	6:26 PM	Flush	<2.0 µg/L
	5/31/2023	7:05:00 AM	LE12A	CR104	S - Sink	5/30/2023	6:39 PM	First Draw	<2.0 µg/L
	5/31/2023	7:05:00 AM	LE12B	CR104	S - Sink	5/30/2023	6:39 PM	Flush	<2.0 µg/L

	5/31/2023	7:07:00 AM	LE13A	CR103	S - Sink	5/30/2023	9:33 PM	First Draw	2.9 µg/L
	5/31/2023	7:07:00 AM	LE13B	CR103	S - Sink	5/30/2023	9:33 PM	Flush	<2.0 µg/L
	5/31/2023	7:10:00 AM	LE14A	CR105	S - Sink	5/30/2023	6:38 PM	First Draw	<2.0 µg/L
	5/31/2023	7:10:00 AM	LE14B	CR105	S - Sink	5/30/2023	6:38 PM	Flush	<2.0 µg/L
	5/31/2023	7:15:00 AM	LE15A	CR106	S - Sink	5/30/2023	6:30 PM	First Draw	<2.0 µg/L
	5/31/2023	7:15:00 AM	LE15B	CR106	S - Sink	5/30/2023	6:30 PM	Flush	<2.0 µg/L
	5/31/2023	7:15:00 AM	LE16A	CR107	S - Sink	5/30/2023	6:34 PM	First Draw	6.7 µg/L
	5/31/2023	7:15:00 AM	LE16B	CR107	S - Sink	5/30/2023	6:34 PM	Flush	<2.0 µg/L
	5/31/2023	7:20:00 AM	LE17A	Library Lounge	S - Sink	5/30/2023	6:32 PM	First Draw	3.1 µg/L
	5/31/2023	7:20:00 AM	LE17B	Library Lounge	S - Sink	5/30/2023	6:32 PM	Flush	<2.0 µg/L
	5/31/2023	7:22:00 AM	LE18A	Gym kitchen	S - Sink	5/30/2023	6:28 PM	First Draw	<2.0 µg/L
	5/31/2023	7:28:00 AM	LE18B	Gym kitchen	S - Sink	5/30/2023	6:28 PM	Flush	<2.0 µg/L
	5/31/2023	7:26:00 AM	LE19A	CR125	S - Sink	5/30/2023	6:26 PM	First Draw	<2.0 µg/L
	5/31/2023	7:26:00 AM	LE19B	CR125	S - Sink	5/30/2023	6:26 PM	Flush	<2.0 µg/L
	5/31/2023	7:33:00 AM	LE20A	Teacher's Lounge 135	S - Sink	5/30/2023	6:22 PM	First Draw	<2.0 µg/L
	5/31/2023	7:33:00 AM	LE20B	Teacher's Lounge 135	S - Sink	5/30/2023	6:22 PM	Flush	<2.0 µg/L
	5/31/2023	7:34:00 AM	LE21A	Workroom by Lounge 135	S - Sink	5/30/2023	6:24 PM	First Draw	2.0 µg/L
	5/31/2023	7:34:00 AM	LE21B	Workroom by Lounge 135	S - Sink	5/30/2023	6:24 PM	Flush	<2.0 µg/L

CR 136 was on the drawing, but had a handwash placard - NOT SAMPLED

CR 108 was not on the drawing, custodian requested sampling but it was not flushed prior to sample date - NOT SAMPLED