

**Indian Trail Elementary School6235 Stonewall St.Downers Grove, IL**

ISBE ID	Sample	Sample	Sample ID	Sample Location Description	Fixture Type	Date of Last	Time of	Sample	Concentration
	6/1/2023	7:35:00 AM	ITES01A	Room25	S - Sink	5/31/2023	6:56 PM	First Draw	2.3 µg/L
	6/1/2023	7:35:00 AM	ITES01B	Room25	S - Sink	5/31/2023	6:56 PM	Flush	<2.0 µg/L
	6/1/2023	7:38:00 AM	ITES02A	Room 24	S - Sink	5/31/2023	6:53 PM	First Draw	<2.0 µg/L
	6/1/2023	7:38:00 AM	ITES21B	Room 24	S - Sink	5/31/2023	6:53 PM	Flush	<2.0 µg/L
	6/1/2023	7:40:00 AM	ITES03A	MPR Kitchen	S - Sink	5/31/2023	6:59 PM	First Draw	<2.0 µg/L
	6/1/2023	7:40:00 AM	ITES03B	MPR Kitchen	S - Sink	5/31/2023	6:59 PM	Flush	<2.0 µg/L
	6/1/2023	7:42:00 AM	ITES04A	MPR	DF - Drinking Fountain	5/31/2023	8:01 PM	First Draw	<2.0 µg/L
	6/1/2023	7:42:00 AM	ITES04B	MPR	BF - Bottle Filler	5/31/2023	8:01 PM	First Draw	<2.0 µg/L
	6/1/2023	7:42:00 AM	ITES04C	MPR	DF - Drinking Fountain	5/31/2023	8:01 PM	Flush	<2.0 µg/L
	6/1/2023	7:48:00 AM	ITES05A	Adjacent Rm 22 Fountain	DF - Drinking Fountain	5/31/2023	7:08 PM	First Draw	<2.0 µg/L
	6/1/2023	7:48:00 AM	ITES05B	Adjacent Rm 22 Fountain	BF - Bottle Filler	5/31/2023	7:08 PM	First Draw	<2.0 µg/L
	6/1/2023	7:48:00 AM	ITES05C	Adjacent Rm 22 Fountain	DF - Drinking Fountain	5/31/2023	7:08 PM	Flush	<2.0 µg/L
	6/1/2023	7:55:00 AM	ITES06A	Room 43	S - Sink	5/31/2023	6:25 PM	First Draw	<2.0 µg/L
	6/1/2023	7:55:00 AM	ITES06B	Room 43	S - Sink	5/31/2023	6:25 PM	Flush	<2.0 µg/L
	6/1/2023	7:57:00 AM	ITES07A	Room 40	S - Sink	5/31/2023	7:04 PM	First Draw	<2.0 µg/L
	6/1/2023	7:57:00 AM	ITES07B	Room 40	S - Sink	5/31/2023	7:04 PM	Flush	<2.0 µg/L
	6/1/2023	8:02:00 AM	ITES08A	Room 44	S - Sink	5/31/2023	6:25 PM	First Draw	<2.0 µg/L
	6/1/2023	8:02:00 AM	ITES08B	Room 44	S - Sink	5/31/2023	6:25 PM	Flush	<2.0 µg/L
	6/1/2023	8:04:00 AM	ITES09A	Room 39	S - Sink	5/31/2023	7:02 PM	First Draw	<2.0 µg/L
	6/1/2023	8:04:00 AM	ITES09B	Room 39	S - Sink	5/31/2023	7:02 PM	Flush	<2.0 µg/L
	6/1/2023	8:06:00 AM	ITES10A	Room 41	S - Sink	5/31/2023	7:06 PM	First Draw	<2.0 µg/L
	6/1/2023	8:06:00 AM	ITES10B	Room 41	S - Sink	5/31/2023	7:06 PM	Flush	<2.0 µg/L
	6/1/2023	8:08:00 AM	ITES11A	Room 9	S - Sink	5/31/2023	6:23 PM	First Draw	<2.0 µg/L
	6/1/2023	8:08:00 AM	ITES11B	Room 9	S - Sink	5/31/2023	6:23 PM	Flush	<2.0 µg/L
	6/1/2023	8:12:00 AM	ITES12A	Room 6	S - Sink	5/31/2023	6:21 PM	First Draw	3.7 µg/L
	6/1/2023	8:12:00 AM	ITES12B	Room 6	S - Sink	5/31/2023	6:21 PM	Flush	<2.0 µg/L
	6/1/2023	8:14:00 AM	ITES13A	Room 5	S - Sink	5/31/2023	6:21 PM	First Draw	48.5 µg/L
	6/1/2023	8:14:00 AM	ITES13B	Room 5	S - Sink	5/31/2023	6:21 PM	Flush	<2.0 µg/L
	6/1/2023	8:17:00 AM	ITES14A	Room 3	S - Sink	5/31/2023	6:19 PM	First Draw	6.9 µg/L







