

Kingsley Elementary School6509 Powell St.Downers Grove, IL

ISBE ID	Sample	Sample	Sample ID	Sample Location Description	Fixture Type	Date of Last	Time of	Sample	Concentration
	6/1/2023	5:36:00 AM	ESES01A	Kitchen Sink	S - Sink	5/31/2023	10:30 PM	First Draw	<2.0 µg/L
	6/1/2023	5:36:00 AM	ESES01B	Kitchen Sink	S - Sink	5/31/2023	10:30 PM	Flush	<2.0 µg/L
	6/1/2023	5:38:00 AM	ESES02A	Hallway outside Kitchen 108	DF - Drinking Fountain	5/31/2023	8:00 PM	First Draw	<2.0 µg/L
	6/1/2023	5:38:00 AM	ESES02B	Hallway outside Kitchen 108	BF - Bottle Filler	5/31/2023	8:00 PM	First Draw	<2.0 µg/L
	6/1/2023	5:40:00 AM	ESES02C	Hallway outside Kitchen 108	DF - Drinking Fountain	5/31/2023	8:00 PM	Flush	<2.0 µg/L
	6/1/2023	5:43:00 AM	ESES03A	Hallway outside Rm112	DF - Drinking Fountain	5/31/2023	6:08 PM	First Draw	<2.0 µg/L
	6/1/2023	5:43:00 AM	ESES03B	Hallway outside Rm112	DF - Drinking Fountain	5/31/2023	6:08 PM	Flush	<2.0 µg/L
	6/1/2023	5:45:00 AM	ESES04A	Hallway outside gymnasium	DF - Drinking Fountain	5/31/2023	8:26 PM	First Draw	<2.0 µg/L
	6/1/2023	5:45:00 AM	ESES04B	Hallway outside gymnasium	DF - Drinking Fountain	5/31/2023	8:26 PM	Flush	<2.0 µg/L
	6/1/2023	5:50:00 AM	ESES05A	Hallway outside Rm121	DF - Drinking Fountain	5/31/2023	8:18 PM	First Draw	<2.0 µg/L
	6/1/2023	5:50:00 AM	ESES05B	Hallway outside Rm121	DF - Drinking Fountain	5/31/2023	8:18 PM	Flush	<2.0 µg/L
	6/1/2023	5:52:00 AM	ESES06A	Hallway outside Kitchen 131	DF - Drinking Fountain	5/31/2023	6:07 PM	First Draw	<2.0 µg/L
	6/1/2023	5:52:00 AM	ESES06B	Hallway outside Kitchen 131	BF - Bottle Filler	5/31/2023	6:07 PM	First Draw	<2.0 µg/L
	6/1/2023	5:53:00 AM	ESES06C	Hallway outside Kitchen 131	DF - Drinking Fountain	5/31/2023	6:07 PM	Flush	<2.0 µg/L
	6/1/2023	5:54:00 AM	ESES07A	Hallway outside NE doors of MPR129	DF - Drinking Fountain	5/31/2023	6:08 PM	First Draw	<2.0 µg/L
	6/1/2023	5:54:00 AM	ESES07B	Hallway outside NE doors of MPR129	DF - Drinking Fountain	5/31/2023	6:08 PM	Flush	<2.0 µg/L
	6/1/2023	5:58:00 AM	ESES08A	Hallway outside Rm138	DF - Drinking Fountain	5/31/2023	6:17 PM	First Draw	<2.0 µg/L
	6/1/2023	5:58:00 AM	ESES08B	Hallway outside Rm138	BF - Bottle Filler	5/31/2023	6:17 PM	First Draw	<2.0 µg/L
	6/1/2023	5:58:00 AM	ESES08C	Hallway outside Rm138	DF - Drinking Fountain	5/31/2023	6:17 PM	Flush	<2.0 µg/L
	6/1/2023	6:03:00 AM	ESES09A	Kitchen 131	S - Sink	5/31/2023	6:06 PM	First Draw	<2.0 µg/L
	6/1/2023	6:03:00 AM	ESES09B	Kitchen 131	S - Sink	5/31/2023	6:06 PM	Flush	<2.0 µg/L
	6/1/2023	6:05:00 AM	ESES10A	Hallway outside Rm 144	DF - Drinking Fountain	5/31/2023	9:20 PM	First Draw	<2.0 µg/L
	6/1/2023	6:05:00 AM	ESES10B	Hallway outside Rm 144	DF - Drinking Fountain	5/31/2023	9:20 PM	Flush	<2.0 µg/L
	6/1/2023	6:07:00 AM	ESES11A	Hallway outside Rm 102	DF - Drinking Fountain	5/31/2023	7:30 PM	First Draw	<2.0 µg/L
	6/1/2023	6:07:00 AM	ESES11B	Hallway outside Rm 102	DF - Drinking Fountain	5/31/2023	7:30 PM	Flush	<2.0 µg/L
	6/1/2023	6:10:00 AM	ESES12A	Rm 100	S - Sink	5/31/2023	7:34 PM	First Draw	<2.0 µg/L
	6/1/2023	6:10:00 AM	ESES12B	Rm 100	S - Sink	5/31/2023	7:34 PM	Flush	<2.0 µg/L
	6/1/2023	6:14:00 AM	ESES13A	Rm 102	S - Sink	5/31/2023	7:40 PM	First Draw	<2.0 µg/L
	6/1/2023	6:14:00 AM	ESES13B	Rm 102	S - Sink	5/31/2023	7:40 PM	Flush	<2.0 µg/L

	6/1/2023	6:20:00 AM	ESES14A	Rm 105	S - Sink	5/31/2023	7:44 PM	First Draw	4.6 µg/L
	6/1/2023	6:20:00 AM	ESES14B	Rm 105	S - Sink	5/31/2023	7:44 PM	Flush	<2.0 µg/L
	6/1/2023	6:25:00 AM	ESES15A	Rm 104	S - Sink	5/31/2023	7:50 PM	First Draw	<2.0 µg/L
	6/1/2023	6:25:00 AM	ESES15B	Rm 104	S - Sink	5/31/2023	7:50 PM	Flush	<2.0 µg/L
	6/1/2023	6:27:00 AM	ESES16A	Rm 106	S - Sink	5/31/2023	7:54 PM	First Draw	<2.0 µg/L
	6/1/2023	6:27:00 AM	ESES16B	Rm 106	S - Sink	5/31/2023	7:54 PM	Flush	<2.0 µg/L
	6/1/2023	6:32:00 AM	ESES17A	Rm 107	S - Sink	5/31/2023	7:58 PM	First Draw	<2.0 µg/L
	6/1/2023	6:32:00 AM	ESES17B	Rm 107	S - Sink	5/31/2023	7:58 PM	Flush	<2.0 µg/L
	6/1/2023	6:35:00 AM	ESES18A	Rm 111	S - Sink	5/31/2023	8:02 PM	First Draw	<2.0 µg/L
	6/1/2023	6:35:00 AM	ESES18B	Rm 111	S - Sink	5/31/2023	8:02 PM	Flush	<2.0 µg/L
	6/1/2023	6:38:00 AM	ESES19A	Rm 117	S - Sink	5/31/2023	8:15 PM	First Draw	<2.0 µg/L
	6/1/2023	6:38:00 AM	ESES19B	Rm 117	S - Sink	5/31/2023	8:15 PM	Flush	<2.0 µg/L
	6/1/2023	6:42:00 AM	ESES20A	Rm 116	S - Sink	5/31/2023	8:24 PM	First Draw	<2.0 µg/L
	6/1/2023	6:42:00 AM	ESES20B	Rm 116	S - Sink	5/31/2023	8:24 PM	Flush	<2.0 µg/L
	6/1/2023	6:44:00 AM	ESES21A	Rm 119	S - Sink	5/31/2023	8:17 PM	First Draw	2.5 µg/L
	6/1/2023	6:44:00 AM	ESES21B	Rm 119	S - Sink	5/31/2023	8:17 PM	Flush	<2.0 µg/L
	6/1/2023	6:48:00 AM	ESES22A	Rm 118	S - Sink	5/31/2023	8:23 PM	First Draw	<2.0 µg/L
	6/1/2023	6:48:00 AM	ESES22B	Rm 118	S - Sink	5/31/2023	8:23 PM	Flush	<2.0 µg/L
	6/1/2023	6:50:00 AM	ESES23A	Rm 121	S - Sink	5/31/2023	8:20 PM	First Draw	<2.0 µg/L
	6/1/2023	6:50:00 AM	ESES23B	Rm 121	S - Sink	5/31/2023	8:20 PM	Flush	<2.0 µg/L
	6/1/2023	6:51:00 AM	ESES24A	Rm 120	S - Sink	5/31/2023	8:22 PM	First Draw	<2.0 µg/L
	6/1/2023	6:51:00 AM	ESES24B	Rm 120	S - Sink	5/31/2023	8:22 PM	Flush	<2.0 µg/L
	6/1/2023	6:55:00 AM	ESES25A	Faculty Lounge 143	S - Sink	5/31/2023	10:01 PM	First Draw	<2.0 µg/L
	6/1/2023	6:55:00 AM	ESES25B	Faculty Lounge 143	S - Sink	5/31/2023	10:01 PM	Flush	<2.0 µg/L
	6/1/2023	7:00:00 AM	ESES26A	Nurse Office	S - Sink	5/31/2023	9:58 PM	First Draw	<2.0 µg/L
	6/1/2023	7:00:00 AM	ESES26B	Nurse Office	S - Sink	5/31/2023	9:58 PM	Flush	<2.0 µg/L
	6/1/2023	7:04:00 AM	ESES27A	Rm 132	S - Sink	5/31/2023	6:10 PM	First Draw	<2.0 µg/L
	6/1/2023	7:04:00 AM	ESES27B	Rm 132	S - Sink	5/31/2023	6:10 PM	Flush	<2.0 µg/L
	6/1/2023	7:05:00 AM	ESES28A	Rm 138	S - Sink	5/31/2023	6:12 PM	First Draw	<2.0 µg/L
	6/1/2023	7:05:00 AM	ESES28B	Rm 138	S - Sink	5/31/2023	6:12 PM	Flush	<2.0 µg/L
	6/1/2023	7:07:00 AM	ESES29A	Rm 133	S - Sink	5/31/2023	6:04 PM	First Draw	<2.0 µg/L

	6/1/2023	7:07:00 AM	ESES29B	Rm 133	S - Sink	5/31/2023	6:04 PM	Flush	<2.0 µg/L
	6/1/2023	7:09:00 AM	ESES30A	Rm 135	S - Sink	5/31/2023	6:03 PM	First Draw	<2.0 µg/L
	6/1/2023	7:09:00 AM	ESES30B	Rm 135	S - Sink	5/31/2023	6:03 PM	Flush	<2.0 µg/L
	6/1/2023	7:10:00 AM	ESES31A	Rm 136	S - Sink	5/31/2023	6:12 PM	First Draw	<2.0 µg/L
	6/1/2023	7:10:00 AM	ESES31B	Rm 136	S - Sink	5/31/2023	6:12 PM	Flush	<2.0 µg/L
	6/1/2023	7:12:00 AM	ESES32A	Rm 137	S - Sink	5/31/2023	6:15 PM	First Draw	<2.0 µg/L
	6/1/2023	7:12:00 AM	ESES32B	Rm 137	S - Sink	5/31/2023	6:15 PM	Flush	<2.0 µg/L
	6/1/2023	7:14:00 AM	ESES33A	Rm 139	S - Sink	5/31/2023	6:14 PM	First Draw	<2.0 µg/L
	6/1/2023	7:14:00 AM	ESES33B	Rm 139	S - Sink	5/31/2023	6:14 PM	Flush	<2.0 µg/L